



Customer: Central States Diesel Generators STK#2675
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 9356
 Test Date 6-1-20

Engine Make/ Model: Cummins 6BT5.9-G6
 Engine Spec/ Serial: 45912533
 Unit Make/ Model: Cummins DGDA-3381449
 Unit Spec/ Serial: K990018826

Voltage: 120/208
 Amperage: 80
 Kilowatts: 222
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	698.3	698.5	698.8	699	699.3	699.4
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	210	210	210	210	210	210
PH2	209	209	209	209	209	209
PH3	210	210	210	210	210	210
Amperage PH1	0	219	220	220	220	0
PH2	0	221	220	219	220	0
PH3	0	220	220	219	220	0
Kilowatts	0	80	80	80	80	0
Oil Pressure	75	71	70	70	70	72
Oil Temperature						
Coolant Temperature	180°F	185°F	185°F	185°F	185°F	183°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	14	14	14	14	14	14
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	70°F	70°F	70°F	70°F	71°F	71°F

Technician Signature: Randy Pool

Customer Signature: _____