



Customer: Central States Diesel Generators STK#2677
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 9374
 Test Date 6-8-20

Engine Make/ Model: GM 5.7L
 Engine Spec/ Serial: 5.7L-7441
 Unit Make/ Model: Katolight N60FPG4
 Unit Spec/ Serial: LM384818 90925-0703

Voltage: 120/208
 Amperage: 167
 Kilowatts: 60 test @50 LP
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	11	11	12	12	12	12
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	210	210	210	210	210	210
PH2	209	209	209	209	209	209
PH3	210	210	210	209	210	210
Amperage PH1	0	139	138	138	139	0
PH2	0	138	139	139	138	0
PH3	0	138	139	138	138	0
Kilowatts	0	50	50	50	50	0
Oil Pressure	60	56	55	55	55	56
Oil Temperature						
Coolant Temperature	157°F	160°F	165°F	165°F	165°F	164°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	13.7	13.7	13.7	13.7	13.7	13.7
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	81°F	81°F	81°F	81°F	82°F	82°F

Technician Signature: _____

Customer Signature: _____