



Customer: Central States Diesel Generators STK#2679

Address: 2001 S Prairie Ave.

City/ State/ Zip Waukesha, WI 53189

Contact: Patrick Paden

Phone: 262-955-7655

R#: 9375

Test Date 7-6-20

Engine Make/ Model: PSI 5.0L

Engine Spec/ Serial: 5POL11831

Unit Make/ Model: Cummins GGPA-7169773

Unit Spec/ Serial: E110216399

Voltage: 120/208

Amperage: 97

Kilowatts: 35

Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	6	6.2	6.5	6.7	7	7.1
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	208	208	209	208	208	208
PH2	208	209	208	208	208	208
PH3	208	208	209	209	208	208
Amperage PH1	0	95	96	96	95	0
PH2	0	95	95	95	95	0
PH3	0	96	95	95	95	0
Kilowatts	0	34	34	34	34	0
Oil Pressure	59	56	55	55	55	57
Oil Temperature						
Coolant Temperature	160°F	175°F	176°F	176°F	176°F	165°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	13.7	13.7	13.7	13.7	13.7	13.7
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	91°F	91°F	91°F	91°F	91°F	91°F

Technician Signature: Randy Pool

Customer Signature: _____