

Great Lakes Industrial Diesel

3-8-21

CSDG: 2683

Generator Check list

Inspection Description

- Yes No NA Check coolant level and record freeze protection: **Full good to -25 deg. F.**
- Yes No NA Visual inspection of radiator: **No visible issues or performance issues**
- Yes No NA Visual inspection of radiator hoses: **No visible issues**
- Yes No NA Check condition of coolant hoses: **No visible issues**
- Yes No NA Check condition of fuel hoses: **No visible issues**
- Yes No NA Check condition of engine belts: **Good working condition**
- Yes No NA Batteries and QTY: **1 group 31 battery that is charged**
- Yes No NA Battery install date if applicable: **Install date marked 2018**
- Yes No NA Genset has battery charger: **Battery charger mounted by gen end**
- Yes No NA Genset has coolant heater: **120VAC coolant heater in engine freeze plug**
- Yes No NA Check engine oil level: **Oil level full**
- Yes No NA Engine oil filters last changed date and HRS: **Last service was 3-8-21/ 796 HRS**
- Yes No NA Inspect exhaust system for cracks / leaks: **No issues with exhaust system**
- Yes No NA Check rain cap for proper operation: **No issues**
- Yes No NA Generator end is 12 lead reconnectable: **12 lead with voltage selector switch**
- Yes No NA Generator end has PMG permanent magnet generator: **No PMG**