



Customer: Central States Diesel Generators STK# 2686
 Address: 2001 S. Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847.997.8090

R#: 9351
 Test Date 2020.06.27

Engine Make/ Model: Cummins NT855-G6
 Engine Spec/ Serial: 30369659 CPL 2116
 Unit Make/ Model: Onan 400DFCE-3493
 Unit Spec/ Serial: D030494078 Spec H

Voltage: 208
 Amperage: 1387.9
 Kilowatts: 400
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	424	424	424	424	425	425
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	208	208	208	208	208	208
PH2	208	208	208	208	208	208
PH3	208	208	208	208	208	208
Amperage PH1	85	360	850	985	1102	0
PH2	85	362	850	984	1105	0
PH3	85	362	849	985	1104	0
Kilowatts	31	130	306	354	397	0
Oil Pressure	75	70	68	63	59	61
Oil Temperature						
Coolant Temperature	174°F	182°F	194°F	196°F	196°F	174°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27	27	27	27	27	27
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	85°F	85°F	85°F	85°F	85°F	85°F

Technician Signature: Jaime Merlo/ John Colini

Customer Signature: _____