



Customer: Central States Diesel Generators STK#2687
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 9395
 Test Date 6-19-20

Engine Make/ Model: Cummins NTA-855-G2
 Engine Spec/ Serial: 30373364
 Unit Make/ Model: Cummins DFCB-5747097
 Unit Spec/ Serial: B060888294

Voltage: 277/480
 Amperage: 361
 Kilowatts: 300
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	241.6	241.8	242.1	242.3	242.6	242.7
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	480	480	480	480	480
PH2	481	481	481	481	481	481
PH3	480	481	480	480	481	480
Amperage PH1	0	361	360	360	360	0
PH2	0	360	361	361	361	0
PH3	0	360	361	361	360	0
Kilowatts	0	300	300	300	300	0
Oil Pressure	52	46	45	45	45	47
Oil Temperature						
Coolant Temperature	182°F	193°F	194°F	194°F	194°F	188°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.9	27.9	27.9	27.9	27.9	27.9
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	87°F	87°F	87°F	87°F	88°F	88°F

Technician Signature: Randy Pool

Customer Signature: _____