



Customer: Central States Diesel Generators STK#2688
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 9393
 Test Date 6-19-20

Engine Make/ Model: Cummins QSX15-G9 NR2
 Engine Spec/ Serial: 79277202
 Unit Make/ Model: Cummins DFEH-7063880
 Unit Spec/ Serial: C080165344

Voltage: 277/480
 Amperage: 481
 Kilowatts: 400
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	268.4	268.6	268.9	269.1	269.4	269.5
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	480	480	480	480	480
PH2	481	481	481	481	481	481
PH3	482	481	482	482	481	482
Amperage PH1	0	481	480	480	481	0
PH2	0	480	481	482	480	0
PH3	0	481	481	481	481	0
Kilowatts	0	400	400	400	400	0
Oil Pressure	44	40	38	38	38	40
Oil Temperature						
Coolant Temperature	178°F	180°F	181°F	181°F	181°F	179°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.3	27.3	27.3	27.3	27.3	27.3
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	85°F	85°F	86°F	86°F	86°F	86°F

Technician Signature: Randy Pool

Customer Signature: _____