



Customer: Central States Diesel Generators STK#2695
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 9410
 Test Date 7-1-20

Engine Make/ Model: Caterpillar 3208
 Engine Spec/ Serial: 29A01314
 Unit Make/ Model: Caterpillar 3208
 Unit Spec/ Serial: 29A01314

Voltage: 277/480
 Amperage: 120
 Kilowatts: 100
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	281.5	281.7	282	282.3	282.5	282.6
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	493	493	493	493	492	492
PH2	492	492	492	492	492	492
PH3	493	492	493	493	493	493
Amperage PH1	0	117	118	117	118	0
PH2	0	118	118	118	117	0
PH3	0	118	117	118	118	0
Kilowatts	0	100	100	100	100	0
Oil Pressure	80	75	75	75	75	77
Oil Temperature						
Coolant Temperature	175°F	180°F	180°F	180°F	180°F	177°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27	27	27	27	27	27
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	78°F	78°F	78°F	79°F	79°F	79°F

Technician Signature: Randy Pool

Customer Signature: _____