



Customer: Central States Diesel Generators STK#2702

Address: 2001 S Prairie Ave.

City/ State/ Zip Waukesha, WI 53189

Contact: Patrick Paden

Phone: 262-955-7655

R#: 9407

Test Date 6-30-20

Engine Make/ Model: Cummins QST30-G5

Engine Spec/ Serial: 37226933

Unit Make/ Model: Cummins DQFAB-5784876

Unit Spec/ Serial: B070018686

Voltage: 277/480

Amperage: 963

Kilowatts: 800

Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	394	394	394	395	395	395
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	479	479	479	479	479	479
PH2	480	479	480	480	479	480
PH3	481	481	481	481	481	481
Amperage PH1	0	964	964	963	963	0
PH2	0	964	963	963	964	0
PH3	0	963	963	963	964	0
Kilowatts	0	800	800	800	800	0
Oil Pressure	68	60	59	59	59	62
Oil Temperature						
Coolant Temperature	171°F	175°F	176°F	176°F	176°F	172°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	26.7	26.7	26.7	26.7	26.7	26.7
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	77°F	77°F	78°F	78°F	78°F	79°F

Technician Signature: Randy Pool

Customer Signature: _____