



Customer: Central States Diesel Generators STK#2705
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 9569
 Test Date 7-23-20

Engine Make/ Model: Cummins KTA-50-G9
 Engine Spec/ Serial: 25273090
 Unit Make/ Model: Cummins 1500DFLE-1540
 Unit Spec/ Serial: L010313583 Spec. B

Voltage: 277/480
 Amperage: 1804
 Kilowatts: 1500
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	407.7	407.9	408.2	408.4	408.7	408.8
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	481	480	480	480	480
PH2	480	480	480	480	480	480
PH3	481	481	481	480	480	480
Amperage PH1	0	1805	1804	1804	1804	0
PH2	0	1804	1805	1803	1805	0
PH3	0	1804	1803	1804	1803	0
Kilowatts	0	1500	1500	1500	1500	0
Oil Pressure	96	80	77	77	77	79
Oil Temperature						
Coolant Temperature	170°F	176°F	176°F	177°F	177°F	174°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	26.8	26.8	26.8	26.8	26.8	26.8
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	71°F	71°F	72°F	72°F	72°F	73°F

Technician Signature: Randy Pool

Customer Signature: _____