



Customer: Central States Diesel Generators STK#2707
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 9408
 Test Date 6-30-20

Engine Make/ Model: Detroit Diesel 6063HV35
 Engine Spec/ Serial: 06R0980011
 Unit Make/ Model: Detroit Diesel 275DSED
 Unit Spec/ Serial: 2168887

Voltage: 277/480
 Amperage: 331
 Kilowatts: 275
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	1612.3	1612.5	1612.8	1613	1613.3	1613.4
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	480	480	480	480	480
PH2	479	479	480	480	479	480
PH3	482	481	482	482	481	482
Amperage PH1	0	331	331	331	330	0
PH2	0	330	330	330	331	0
PH3	0	330	331	331	331	0
Kilowatts	0	275	275	275	275	0
Oil Pressure	60	54	53	53	53	56
Oil Temperature						
Coolant Temperature	180°F	185°F	185°F	185°F	185°F	182°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.2	27.2	27.2	27.2	27.2	27.2
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	85°F	85°F	85°F	86°F	86°F	86°F

Technician Signature: Randy Pool

Customer Signature: _____