



**GENERAC**

Customer: Central States Diesel Generators STK#2710  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip: Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 262-955-7655

R#: 9479  
 Test Date: 7-29-20

Engine Make/ Model: HINO EK130  
 Engine Spec/ Serial: A11206  
 Unit Make/ Model: Generac 20A03035-S  
 Unit Spec/ Serial: 2058195

Voltage: 120/208  
 Amperage: 555  
 Kilowatts: 200  
 Power Factor: 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	130	130.2	130.5	130.7	131	131.1
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	207	207	207	207	207	207
PH2	208	208	209	208	208	208
PH3	207	208	207	207	207	207
Amperage PH1	0	555	554	556	555	0
PH2	0	554	555	554	556	0
PH3	0	556	554	554	554	0
Kilowatts	0	200	200	200	200	0
Oil Pressure	120	107	106	106	106	110
Oil Temperature						
Coolant Temperature	180°F	198°F	198°F	199°F	199°F	189°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.6	27.6	27.6	27.6	27.6	27.6
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	77°F	77°F	78°F	78°F	78°F	78°F

Technician Signature: Randy Pool

Customer Signature: \_\_\_\_\_