



Customer: Central States Diesel Generators STK#2714  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 262-995-7655

R#: 9559  
 Test Date 7-16-2020

Engine Make/ Model: Ford LSG-875I-6005-A  
 Engine Spec/ Serial: 14197-1-04-98  
 Unit Make/ Model: Cummins GGHD-3375522  
 Unit Spec/ Serial: G990954785 Spec. B

Voltage: 120/208  
 Amperage: 277  
 Kilowatts: 100  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	413.9	414.2	414.4	414.7	414.9	415
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	209	209	208	209	209	209
PH2	209	209	209	209	209	209
PH3	209	208	209	208	209	209
Amperage PH1	0	278	277	277	277	0
PH2	0	277	277	278	277	0
PH3	0	278	277	277	277	0
Kilowatts	0	100	100	100	100	0
Oil Pressure	OK	OK	OK	OK	OK	OK
Oil Temperature						
Coolant Temperature	180°F	180°F	180°F	180°F	180°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	14	14	14	14	14	14
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	77°F	77°F	77°F	78°F	78°F	78°F

Technician Signature: \_\_\_\_\_

Customer Signature: \_\_\_\_\_