



Customer: Central States Diesel Generators STK#2717
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 9588
 Test Date 8-4-20

Engine Make/ Model: Caterpillar 3412
 Engine Spec/ Serial: 1EZ08072
 Unit Make/ Model: Caterpillar 3412
 Unit Spec/ Serial: 1EZ08072

Voltage: 277/480
 Amperage: 902
 Kilowatts: 750
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	412	412	412	413	413	413
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	481	481	481	480	481	481
PH2	480	480	480	480	480	480
PH3	480	480	480	481	480	480
Amperage PH1	0	902	902	901	902	0
PH2	0	901	902	903	902	0
PH3	0	902	903	902	903	0
Kilowatts	0	750	750	750	750	0
Oil Pressure	85	75	72	71	71	76
Oil Temperature	190°F	200°F	203°F	203°F	203°F	190°F
Coolant Temperature	180°F	186°F	187°F	187°F	187°F	182°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27	27	27	27	27	27
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	70°F	70°F	70°F	70°F	70°F	70°F

Technician Signature: _____

Customer Signature: _____