



Customer: Central States Diesel Generators STK#2720  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 262-955-7655

R#: 9583  
 Test Date 7-28-20

Engine Make/ Model: Cummins 6CT8.3-G2  
 Engine Spec/ Serial: 46056882  
 Unit Make/ Model: Cummins DGEA-4493286  
 Unit Spec/ Serial: L000185827 Spec. L

Voltage: 120/208  
 Amperage: 347  
 Kilowatts: 125  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	214.7	214.9	215.2	215.4	215.7	215.8
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	207	207	207	207	207	207
PH2	208	208	209	207	208	208
PH3	207	207	207	207	207	207
Amperage PH1	0	348	347	348	348	0
PH2	0	347	347	347	347	0
PH3	0	348	347	348	348	0
Kilowatts	0	125	125	125	125	0
Oil Pressure	60	56	55	55	54	57
Oil Temperature						
Coolant Temperature	180°F	185°F	185°F	185°F	185°F	184°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	13.7	13.7	13.7	13.7	13.7	13.7
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	75°F	75°F	75°F	75°F	75°F	76°F

Technician Signature: Randy Pool

Customer Signature: \_\_\_\_\_