



Customer: Central States Diesel Generators STK#2721
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 9693
 Test Date 9-1-20

Engine Make/ Model: Caterpillar 3412
 Engine Spec/ Serial: 81Z23038
 Unit Make/ Model: Caterpillar 3412
 Unit Spec/ Serial: 81Z23038

Voltage: 277/480
 Amperage: 722
 Kilowatts: 600
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	665	665	665	666	666	666
Hertz/Cycles	60.2	60.2	60.2	60.2	60.2	60.2
Voltage PH1	483	483	483	483	483	483
PH2	481	474	474	474	474	481
PH3	480	478	478	478	478	480
Amperage PH1	0	721	724	724	724	0
PH2	0	720	726	726	726	0
PH3	0	722	724	724	724	0
Kilowatts	0	600	600	600	600	0
Oil Pressure	75	70	66	66	66	72
Oil Temperature						
Coolant Temperature	180°F	198°F	198°F	197°F	198°F	182°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	25.7	25.7	25.7	25.7	25.7	25.7
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	68°F	68°F	68°F	68°F	68°F	68°F

Technician Signature: Randy Pool

Customer Signature: _____