



Customer: Central States Diesel Generators STK#2724
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 9591
 Test Date 8-6-20

Engine Make/ Model: Caterpillar 3306
 Engine Spec/ Serial: 9NR04111
 Unit Make/ Model: Caterpillar SR4B
 Unit Spec/ Serial: 7YR01991

Voltage: 120/208
 Amperage: 866
 Kilowatts: 250
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	678	678	678	679	679	679
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	210	210	210	210	210	210
PH2	209	209	209	209	209	209
PH3	210	210	210	210	210	210
Amperage PH1	0	692	689	691	690	0
PH2	0	691	691	690	691	0
PH3	0	692	690	690	690	0
Kilowatts	0	250	250	250	250	0
Oil Pressure	80	77	76	76	76	78
Oil Temperature						
Coolant Temperature	170°F	175°F	175°F	175°F	175°F	172°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	24	24	24	24	24	24
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	68°F	68°F	68°F	68°F	69°F	69°F

Technician Signature: Randy Pool

Customer Signature: _____