



Customer: Central States Diesel Generators STK#2725
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 9592
 Test Date 9-24-20

Engine Make/ Model: Caterpillar 3306
 Engine Spec/ Serial: 9NR03589
 Unit Make/ Model: Caterpillar 3306
 Unit Spec/ Serial: 9NR03589

Voltage: 277/480
 Amperage: 301
 Kilowatts: 250
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	406	406	406	406	407	407
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	480	480	480	480	480
PH2	480	480	480	480	480	480
PH3	480	480	480	480	480	480
Amperage PH1	0	300	301	301	301	0
PH2	0	301	300	300	300	0
PH3	0	302	302	301	302	0
Kilowatts	0	250	250	250	250	0
Oil Pressure	64	59	58	58	58	60
Oil Temperature						
Coolant Temperature	175°F	182°F	183°F	183°F	183°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27	27	27	27	27	27
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	72°F	72°F	72°F	73°F	73°F	73°F

Technician Signature: Randy Pool

Customer Signature: _____