



Customer: Central States Diesel Generators STK# 2727
 Address: 2001 S. Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847.997.8090

R#: 9612
 Test Date 2020.08.05

Engine Make/ Model: CUMMINS QST30G5
 Engine Spec/ Serial: 37200763
 Unit Make/ Model: CUMMINS/ ONAN 1000DFHD-2411
 Unit Spec/ Serial: J010296132 B

Voltage: 480
 Amperage: 1503.6
 Kilowatts: 1000
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	538.4	538.7	538.9	539.2	539.4	539.4
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	480	480	480	480	480
PH2	480	480	480	480	480	480
PH3	480	480	480	480	480	480
Amperage PH1	137	421	856	1199	1198	0
PH2	135	420	854	1200	1200	0
PH3	135	421	856	1200	1199	0
Kilowatts	113	349	710	996	996	0
Oil Pressure	72	67	63	60	58	60
Oil Temperature						
Coolant Temperature	171°F	176°F	178°F	181°F	182°F	174°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27	27	27	27	27	27
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	75°F	75°F	75°F	75°F	75°F	75°F

Technician Signature: John Colini

Customer Signature: _____