



Customer: Central States Diesel Generators STK#2729  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 262-955-7655

R#: 10199  
 Test Date 10-29-20

Engine Make/ Model: Cummins QST30-G5  
 Engine Spec/ Serial: 37226474  
 Unit Make/ Model: Cummins DQFAB-5780851  
 Unit Spec/ Serial: A070013150 Spec. A

Voltage: 277/480  
 Amperage: 962  
 Kilowatts: 800  
 Power Factor 1.0

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	291.7	291.9	292.2	292.4	292.7	292.8
Hertz/Cycles	60.1	60.1	60.1	60.1	60.1	60.1
Voltage PH1	481	480	480	481	481	481
PH2	480	480	480	480	481	480
PH3	480	479	480	479	479	480
Amperage PH1	0	964	965	964	964	0
PH2	0	963	962	961	963	0
PH3	0	965	963	965	963	0
Kilowatts	0	801	800	800	801	0
Oil Pressure	60	56	55	54	54	56
Oil Temperature	180°F	199°F	199°F	199°F	199°F	189°F
Coolant Temperature	172°F	174°F	175°F	175°F	174°F	173°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	26.7	26.7	26.7	26.7	26.7	26.7
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	37°F	37°F	37°F	38°F	38°F	38°F

Technician Signature: \_\_\_\_\_

Customer Signature: \_\_\_\_\_