



Customer: Central States Diesel Generators STK#2730

Address: 2001 S Prairie Ave.

City/ State/ Zip Waukesha, WI 53189

Contact: Patrick Paden

Phone: 262-995-7655

R#: 9642

Test Date 8-7-2020

Engine Make/ Model: MTU Detroit Diesel 6063TK35R

Engine Spec/ Serial: 06R0706556

Unit Make/ Model: Kohler 350RE0ZD

Unit Spec/ Serial: GM113280-GA3 0742952

Voltage: 277/480

Amperage: 534

Kilowatts: 355

Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	404.5	404.7	405	405.2	405.5	405.6
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	479	479	480	479	479	479
PH2	480	480	480	480	480	480
PH3	481	481	481	481	481	481
Amperage PH1	0	428	428	428	428	0
PH2	0	427	427	427	427	0
PH3	0	427	426	426	427	0
Kilowatts	0	355	355	355	355	0
Oil Pressure	40	36	35	35	35	38
Oil Temperature						
Coolant Temperature	185°F	190°F	190°F	190°F	190°F	185°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28.2	28.2	28.2	28.2	28.2	28.2
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	74°F	74°F	75°F	75°F	75°F	75°F

Technician Signature: Randy Pool

Customer Signature: \_\_\_\_\_