



Customer: Central States Diesel Generators STK#2731
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-995-7655

R#: 9649
 Test Date 8-12-2020

Engine Make/ Model: Mitsubishi S6R-PTA
 Engine Spec/ Serial: 16143
 Unit Make/ Model: EDI-600-M
 Unit Spec/ Serial: 16143

Voltage: 277/480
 Amperage: 722
 Kilowatts: 600
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	397.3	397.5	397.8	398	398.3	398.4
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	486	486	485	486	486	486
PH2	485	485	485	485	485	485
PH3	485	485	486	485	485	485
Amperage PH1	0	715	716	714	715	0
PH2	0	714	715	715	714	0
PH3	0	714	714	715	714	0
Kilowatts	0	600	600	600	600	0
Oil Pressure	60	56	54	54	54	58
Oil Temperature						
Coolant Temperature	185°F	194°F	194°F	194°F	194°F	188°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28	28	28	28	28	28
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	75°F	75°F	75°F	75°F	76°F	76°F

Technician Signature: Randy Pool 8-12-20

Customer Signature: _____