



Customer: Central States Diesel Generators STK#2732  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 262-955-7655

R#: 9691  
 Test Date 8-20-20

Engine Make/ Model: Volvo Penta TWD731VE  
 Engine Spec/ Serial: 206\*158254  
 Unit Make/ Model: MQ Power TWD731VE 431PSL6206  
 Unit Spec/ Serial: 2071158254 LM-241668-0802

Voltage: 277/480 (multi-select)  
 Amperage: 240  
 Kilowatts: 200  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	2711.1	2711.3	2711.6	2711.8	2712.1	2712.2
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	481	481	480	481	481	481
PH2	481	480	481	481	481	481
PH3	481	481	480	481	481	481
Amperage PH1	0	240	241	241	240	0
PH2	0	241	240	240	241	0
PH3	0	240	240	241	240	0
Kilowatts	0	200	200	200	200	0
Oil Pressure	70	62	61	61	61	64
Oil Temperature						
Coolant Temperature	180°F	195°F	196°F	195°F	195°F	186°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28	28	28	28	28	28
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	81°F	81°F	81°F	81°F	82°F	82°F

Technician Signature: \_\_\_\_\_

Customer Signature: \_\_\_\_\_