



Customer: Central States Diesel Generators #2733
 Address: 2001 S. Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847.997.8090

R#: 9690
 Test Date 2020.08.21

Engine Make/ Model: VOLVO TWD731VE
 Engine Spec/ Serial: 2071158671
 Unit Make/ Model: MQ 481PSL6206
 Unit Spec/ Serial: LM-241638-0802

Voltage: 480
 Amperage: 301
 Kilowatts: 200
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	2901				2902	2902
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	482	483	483	482	484	482
PH2	482	483	482	484	483	482
PH3	482	483	482	482	483	482
Amperage PH1	35	123	245	244	246	0
PH2	35	127	244	244	243	0
PH3	36	125	239	241	241	0
Kilowatts	29	104	202	203	203	0
Oil Pressure	75	67	62	61	59	63
Oil Temperature						
Coolant Temperature	150°F	175°F	195°F	195°F	195°F	165°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27	27	27	27	27	27
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	90°F	90°F	90°F	90°F	90°F	90°F

Technician Signature: John Colini

Customer Signature: _____