



Customer: Central States Diesel Generators STK#2734  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 262-955-7655

R#: 9709  
 Test Date 8-20-20

Engine Make/ Model: Yanmar 4TN84  
 Engine Spec/ Serial: 30156  
 Unit Make/ Model: Kohler 20RCOZN  
 Unit Spec/ Serial: PA-135325-R 0692937

Voltage: 277/480 (multi-select)  
 Amperage: 24  
 Kilowatts: 20  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	3239.5	3239.7	3240	3240.2	3240.5	3240.6
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	479	479	479	479	479	479
PH2	480	479	479	480	479	479
PH3	479	479	479	479	478	479
Amperage PH1	0	24	24	23	24	0
PH2	0	24	24	24	24	0
PH3	0	23	23	24	24	0
Kilowatts	0	20	20	20	20	0
Oil Pressure	30	26	25	25	25	26
Oil Temperature						
Coolant Temperature	185°F	195°F	200°F	200°F	200°F	190°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	13.8	13.8	13.8	13.8	13.8	13.8
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	82°F	82°F	82°F	82°F	83°F	83°F

Technician Signature: Randy Pool

Customer Signature: \_\_\_\_\_