



Customer: Central States Diesel Generators STK#2735
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 9710
 Test Date 8-21-20

Engine Make/ Model: Yanmar 4TN84TE-RKRV
 Engine Spec/ Serial: 30156
 Unit Make/ Model: Kohler 20RCZN
 Unit Spec/ Serial: 135325-R 0661677

Voltage: 277/480 (multi-select)
 Amperage: 24
 Kilowatts: 20
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	4587.9	4588.1	4588.4	4588.6	4588.9	4589
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	485	485	485	485	485	485
PH2	484	485	484	484	485	485
PH3	487	488	488	487	488	487
Amperage PH1	0	24	23	24	24	0
PH2	0	23	23	23	23	0
PH3	0	23	24	23	24	0
Kilowatts	0	20	20	20	20	0
Oil Pressure	35	30	30	30	30	34
Oil Temperature						
Coolant Temperature	185°F	200°F	200°F	200°F	200°F	190°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	13.8	13.8	13.8	13.8	13.8	13.8
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	82°F	82°F	83°F	83°F	83°F	83°F

Technician Signature: Randy Pool

Customer Signature: _____