



Customer: Central States Diesel Generators STK#2736  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 262-955-7655

R#: 9711  
 Test Date 8-21-20

Engine Make/ Model: Yanmar 4TN84  
 Engine Spec/ Serial: 29777  
 Unit Make/ Model: NO TAG  
 Unit Spec/ Serial: NO TAG

Voltage: 277/480 (multi-select)  
 Amperage: 24  
 Kilowatts: 20  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	351	351.3	351.5	351.7	352	352.1
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	483	483	483	483	483	483
PH2	482	482	482	482	482	482
PH3	483	483	483	483	483	483
Amperage PH1	0	24	23	24	24	0
PH2	0	24	24	24	23	0
PH3	0	23	24	23	24	0
Kilowatts	0	20	20	20	20	0
Oil Pressure	35	31	30 Min.	30	30	33
Oil Temperature						
Coolant Temperature	185°F	195°F	205°F	205°F	205°F	190°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	13.9	13.9	13.9	13.9	13.9	13.9
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	81°F	81°F	81°F	81°F	82°F	82°F

Technician Signature: Randy Pool

Customer Signature: \_\_\_\_\_