



Customer: Central States Diesel Generators STK#2737
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 9692
 Test Date 8-24-20

Engine Make/ Model: Cummins VTA-28-G5
 Engine Spec/ Serial: 25242443
 Unit Make/ Model: Cummins DFGB-3368703
 Unit Spec/ Serial: D990897909

Voltage: 277/480
 Amperage: 722
 Kilowatts: 600
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	672.6	672.8	673.1	673.3	673.6	673.7
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	482	482	482	482	482	482
PH2	483	483	482	483	483	483
PH3	482	482	483	482	482	482
Amperage PH1	0	721	720	722	721	0
PH2	0	720	721	721	722	0
PH3	0	721	720	720	720	0
Kilowatts	0	600	600	600	600	0
Oil Pressure	58	54	53	53	53	55
Oil Temperature	190°F	210°F	211°F	211°F	211°F	195°F
Coolant Temperature	185°F	198°F	199°F	199°F	199°F	187°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp		795°F	797°F	796°F	795°F	
R/B Exhaust Temp		812°F	814°F	815°F	814°F	
Exhaust Temperature						
DC Voltage	28	28	28	28	28	28
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	79°F	79°F	79°F	79°F	80°F	80°F

Technician Signature: Randy Pool

Customer Signature: _____