



Customer: Central States Diesel Generators STK#2739
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 9695
 Test Date 8-25-20

Engine Make/ Model: Cummins QSX15-G9 NR2
 Engine Spec/ Serial: 79333686
 Unit Make/ Model: Cummins DFEG-7232162
 Unit Spec/ Serial: H080205231 Spec.F

Voltage: 120/208
 Amperage: 972
 Kilowatts: 350
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	740	740	741	741	741	741
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	208	206	206	206	206	208
PH2	208	207	207	207	207	208
PH3	207	206	206	206	206	207
Amperage PH1	0	994	995	994	994	0
PH2	0	1002	1001	1002	1001	0
PH3	0	955	956	954	955	0
Kilowatts	0	350	350	350	350	0
Oil Pressure	42	38	36	36	36	39
Oil Temperature	198°F	228°F	228°F	228°F	228°F	220°F
Coolant Temperature	176°F	180°F	180°F	180°F	180°F	178°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.3	27.3	27.3	27.3	27.3	27.3
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	81°F	81°F	81°F	82°F	82°F	82°F

Technician Signature: Randy Pool

Customer Signature: _____