



Customer: Central States Diesel Generators STK#2741
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 9794
 Test Date 8-27-20

Engine Make/ Model: Cummins NTA-855-G6
 Engine Spec/ Serial: 11712319
 Unit Make/ Model: Cummins 275DFBF
 Unit Spec/ Serial: 65263H L930527283

Voltage: 277/480
 Amperage: 331
 Kilowatts: 275
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	634	634.2	634.5	634.7	635	635.1
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	482	481	481	481	481	482
PH2	481	480	480	480	480	481
PH3	481	481	481	481	481	481
Amperage PH1	0	330	331	330	330	0
PH2	0	331	330	330	330	0
PH3	0	331	330	330	330	0
Kilowatts	0	275	275	275	275	0
Oil Pressure	50	46	42	42	42	44
Oil Temperature						
Coolant Temperature	175°F	180°F	180°F	180°F	180°F	176°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28.4	28.4	28.4	28.4	28.4	28.4
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	83°F	83°F	83°F	84°F	84°F	84°F

Technician Signature: Randy Pool

Customer Signature: _____