



Customer: Central States Diesel Generators STK#2742
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 9795
 Test Date 9-1-20

Engine Make/ Model: Perkins 1300
 Engine Spec/ Serial: WJ1296N1188389*
 Unit Make/ Model: Olympian D200P1
 Unit Spec/ Serial: E4148E/001

Voltage: 120/208
 Amperage: 555
 Kilowatts: 200
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	847.7	848	848.2	848.5	848.7	848.8
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	208	208	208	208	208	208
PH2	208	208	208	208	208	208
PH3	208	208	208	208	208	208
Amperage PH1	0	554	555	556	555	0
PH2	0	555	556	555	554	0
PH3	0	555	554	554	555	0
Kilowatts	0	200	200	200	200	0
Oil Pressure	75	68	67	67	67	69
Oil Temperature						
Coolant Temperature	180°F	195°F	196°F	196°F	195°F	182°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	24	24	24	24	24	24
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	70°F	70°F	70°F	71°F	71°F	71°F

Technician Signature: Randy Pool

Customer Signature: _____