



Customer: Central States Diesel Generators STK#2744
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 10151
 Test Date 9-29-20

Engine Make/ Model: Cummins QSB7-G5 NR3
 Engine Spec/ Serial: 73589938
 Unit Make/ Model: Cummins DSGAA-1339537
 Unit Spec/ Serial: J130585971 Spec. L

Voltage: 277/480
 Amperage: 120
 Kilowatts: 100
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	151.4	151.6	151.9	152.1	152.4	152.5
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	474	474	474	474	474	474
PH2	473	473	473	474	473	473
PH3	474	474	474	474	474	474
Amperage PH1	0	122	122	122	122	0
PH2	0	121	121	122	121	0
PH3	0	122	122	121	122	0
Kilowatts	0	100	100	100	100	0
Oil Pressure	54	50	49	49	49	52
Oil Temperature						
Coolant Temperature	175°F	179°F	179°F	179°F	179°F	175°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	14.1	14.1	14.1	14.1	14.1	14.1
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	57°F	57°F	57°F	57°F	57°F	57°F

Technician Signature: Randy Pool

Customer Signature: _____