



Customer: Central States Diesel Generators STK#2745
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 10142
 Test Date 10-6-20

Engine Make/ Model: John Deere 4045HF275
 Engine Spec/ Serial: PE4045H504220
 Unit Make/ Model: Kohler 100REOZJC
 Unit Spec/ Serial: 2061342 Spec. GM30990-GA3

Voltage: 120/208
 Amperage: 277
 Kilowatts: 100
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	80.9	81.2	81.5	81.7	81.9	82
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	208	206	206	206	206	208
PH2	209	210	210	210	210	209
PH3	208	208	208	208	208	208
Amperage PH1	0	278	278	279	278	0
PH2	0	275	275	276	275	0
PH3	0	277	277	277	277	0
Kilowatts	0	100	100	100	100	0
Oil Pressure	54	50	49	49	49	52
Oil Temperature						
Coolant Temperature	180°F	185°F	185°F	186°F	185°F	182°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	13.8	13.8	13.8	13.8	13.8	13.8
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	65°F	65°F	65°F	66°F	66°F	66°F

Technician Signature: _____

Customer Signature: _____