



Customer: Central States Diesel Generators STK#2754
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 9864
 Test Date 9-10-20

Engine Make/ Model: Cummins KTA19-G4
 Engine Spec/ Serial: 37176635
 Unit Make/ Model: Cummins 500DFED
 Unit Spec/ Serial: F970641806 Spec.88552C

Voltage: 277/480
 Amperage: 601
 Kilowatts: 500
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	895.8	896	896.3	896.5	896.8	896.9
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	481	481	481	481	208
PH2	480	481	481	481	481	208
PH3	480	481	481	481	481	207
Amperage PH1	0	601	602	602	601	0
PH2	0	602	601	601	602	0
PH3	0	601	601	602	601	0
Kilowatts	0	500	500	500	500	0
Oil Pressure	74	68	67	67	67	70
Oil Temperature	190°F	200°F	200°F	200°F	200°F	190°F
Coolant Temperature	177°F	183°F	184°F	184°F	184°F	178°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.8	27.8	27.8	27.8	27.8	27.8
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	51°F	51°F	52°F	52°F	52°F	53°F

Technician Signature: Randy Pool

Customer Signature: _____