



Customer: Central States Diesel Generators STK#2756  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 262-955-7655

R#: 9865  
 Test Date 9-11-20

Engine Make/ Model: John Deere 4045TF  
 Engine Spec/ Serial: PE4045T482683  
 Unit Make/ Model: Kohler 60REOZJB  
 Unit Spec/ Serial: 2052939 Spec. GM21199-GA17

Voltage: 120/240 1PH  
 Amperage: 242  
 Kilowatts: 58  
 Power Factor 1

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	37.8	38	38.3	38.5	38.8	38.9
Hertz/Cycles	60	60	60	60	60	60
Voltage A-B	242	241	242	242	242	242
A-N	121	122	121	121	121	122
B-N	122	121	122	122	122	121
Amperage PH1	0	57	58	57	57	0
PH2	0	58	57	58	58	0
PH3	0	0	0	0	0	0
Kilowatts	0	58	58	58	58	0
Oil Pressure	64	59	58	58	58	62
Oil Temperature						
Coolant Temperature	165°F	176°F	176°F	176°F	176°F	163°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	14.2	14.2	14.2	14.2	14.2	14.2
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	51°F	51°F	51°F	51°F	51°F	51°F

Technician Signature: Randy Pool

Customer Signature: \_\_\_\_\_