



Customer: Central States Diesel Generators STK#2757  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 262-955-7655

R#: 9866  
 Test Date 9-16-20

Engine Make/ Model: John Deere 4045TF270  
 Engine Spec/ Serial: PE4045T486907  
 Unit Make/ Model: Kohler 60REOZJB  
 Unit Spec/ Serial: 2052945 Spec. GM21199-GA17

Voltage: 120/240 1PH  
 Amperage: 242  
 Kilowatts: 58  
 Power Factor 1

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	97.2	97.4	97.7	97.9	98.2	98.3
Hertz/Cycles	60	60	60	60	60	60
Voltage A-B	240	240	240	240	240	240
A-N	120	123	123	123	123	120
B-N	120	117	118	118	117	120
Amperage PH1	0	240	241	240	240	0
PH2	0	241	241	242	241	0
PH3	0	0	0	0	0	0
Kilowatts	0	58	58	58	58	0
Oil Pressure	60	57	56	56	56	59
Oil Temperature						
Coolant Temperature	165°F	173°F	173°F	173°F	173°F	170°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	14.4	14.4	14.4	14.4	14.4	14.4
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	67°F	67°F	67°F	68°F	68°F	68°F

Technician Signature: Randy Pool

Customer Signature: \_\_\_\_\_