



Customer: Central States Diesel Generators STK#2760
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 10180
 Test Date 10-23-20

Engine Make/ Model: Caterpillar 3412
 Engine Spec/ Serial: 81Z12623
 Unit Make/ Model: Caterpillar 3412 SR4
 Unit Spec/ Serial: 6FA07763

Voltage: 277/480
 Amperage: 722
 Kilowatts: 600
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	660	660	661	661	661	661
Hertz/Cycles	59.8	59.3	59.3	59.3	59.3	59.8
Voltage PH1	483	484	483	484	483	483
PH2	483	483	482	483	482	483
PH3	484	484	484	484	484	484
Amperage PH1	0	719	718	718	719	0
PH2	0	718	718	719	718	0
PH3	0	719	718	719	719	0
Kilowatts	0	600	600	600	600	0
Oil Pressure	78	72	70	70	70	73
Oil Temperature						
Coolant Temperature	180°F	182°F	183°F	183°F	183°F	181°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	25	25	25	25	25	25
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	42°F	42°F	42°F	41°F	41°F	41°F

Technician Signature: _____

Customer Signature: _____