



Customer: Central States Diesel Generators STK#2762
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 9934
 Test Date 9-16-20

Engine Make/ Model: Ford LSG-875I-6005-A Nat. Gas
 Engine Spec/ Serial: 83159-1-07-00
 Unit Make/ Model: Cummins GGHC-4489853
 Unit Spec/ Serial: K000169218 Spec. B

Voltage: 120/240 1PH
 Amperage: 333
 Kilowatts: 80 Test@60 LP
 Power Factor 1

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	761.5	761.7	762	762.2	762.5	762.6
Hertz/Cycles	60	60	60	60	60	60
Voltage A-B	240	240	240	240	240	240
A-N	120	121	120	121	121	120
B-N	120	120	120	120	121	120
Amperage PH1	0	251	251	250	251	0
PH2	0	250	250	251	250	0
PH3	0	0	0	0	0	0
Kilowatts	0	60	60	60	60	0
Oil Pressure	80	75	73	73	73	75
Oil Temperature						
Coolant Temperature	180°F	182°F	182°F	183°F	182°F	181°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	13.8	13.8	13.8	13.8	13.8	13.8
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	81°F	81°F	81°F	81°F	81°F	80°F

Technician Signature: Randy Pool

Customer Signature: _____