



Customer: Central States Diesel Generators STK#2763
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 9939
 Test Date 9-18-20

Engine Make/ Model: Cummins 6CT8.3-G2
 Engine Spec/ Serial: 46056878
 Unit Make/ Model: Cummins DGEA-4493284
 Unit Spec/ Serial: L000185826 Spec. L

Voltage: 120/208
 Amperage: 347
 Kilowatts: 125
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	434.5	434.7	435	435.2	435.5	435.6
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	208	208	208	208	208	208
PH2	208	208	208	208	208	208
PH3	208	208	208	208	208	208
Amperage PH1	0	347	348	347	347	0
PH2	0	348	347	347	347	0
PH3	0	347	348	347	347	0
Kilowatts	0	125	125	125	125	0
Oil Pressure	60	56	55	55	55	57
Oil Temperature						
Coolant Temperature	180°F	185°F	185°F	185°F	185°F	183°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	13.7	13.7	13.7	13.7	13.7	13.7
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	65°F	65°F	65°F	65°F	65°F	66°F

Technician Signature: Randy Pool

Customer Signature: _____