



Customer: Central States Diesel Generators STK#2764
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 9932
 Test Date 9-21-20

Engine Make/ Model: GM 8.1L
 Engine Spec/ Serial: 13131 K08
 Unit Make/ Model: Katolight SEN100FPG4 29414
 Unit Spec/ Serial: 131466-0906

Voltage: 120/208
 Amperage: 277
 Kilowatts: 100 Test@40 LP
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	169	169	169	170	170	170
Hertz/Cycles	60	60	60	60	60	60
Voltage A-B	208	206	207	206	206	208
A-N	207	206	206	207	206	207
B-N	208	207	207	206	207	208
Amperage PH1	0	111	112	112	111	0
PH2	0	112	111	112	112	0
PH3	0	112	111	111	112	0
Kilowatts	0	40	40	40	40	0
Oil Pressure	58	56	55	55	55	57
Oil Temperature						
Coolant Temperature	160°F	160°F	160°F	160°F	160°F	160°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	13.8	13.8	13.8	13.8	13.8	13.8
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	65°F	65°F	66°F	66°F	66°F	67°F

Technician Signature: Randy Pool

Customer Signature: _____