



Customer: Central States Diesel Generators STK#2766
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 9938
 Test Date 9-18-20

Engine Make/ Model: Cummins 6BT5.9-G6
 Engine Spec/ Serial: 45848932
 Unit Make/ Model: Cummins DGDB-3372745
 Unit Spec/ Serial: E990916317 Spec. M

Voltage: 277/480
 Amperage: 121
 Kilowatts: 100
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	998	998.2	998.5	998.7	999	999.1
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	481	481	481	481	481	481
PH2	480	480	480	480	480	480
PH3	481	481	481	480	481	481
Amperage PH1	0	120	121	120	121	0
PH2	0	121	120	121	120	0
PH3	0	121	121	120	121	0
Kilowatts	0	100	100	100	100	0
Oil Pressure	42	38	36	36	36	39
Oil Temperature						
Coolant Temperature	176°F	180°F	180°F	180°F	180°F	178°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	14	14	14	14	14	14
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	71°F	71°F	71°F	72°F	72°F	72°F

Technician Signature: Randy Pool

Customer Signature: _____