



Customer: Central States Diesel Generators STK#2767
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 10197
 Test Date 11-10-20

Engine Make/ Model: Cummins 6CTA8.3-G
 Engine Spec/ Serial: 45617598
 Unit Make/ Model: Cummins 150DGFA
 Unit Spec/ Serial: K970658900 Spec. 92020K

Voltage: 277/480
 Amperage: 181
 Kilowatts: 150
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	289.3	289.5	289.8	290	290.3	290.4
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	480	480	480	480	480
PH2	480	479	479	480	479	480
PH3	480	480	479	480	479	480
Amperage PH1	0	180	181	181	181	0
PH2	0	182	181	180	181	0
PH3	0	181	181	181	181	0
Kilowatts	0	150	150	150	150	0
Oil Pressure	70	67	65	65	65	67
Oil Temperature						
Coolant Temperature	175°F	190°F	190°F	191°F	190°F	178°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	13.8	13.8	13.8	13.8	13.8	13.8
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	60°F	60°F	61°F	61°F	61°F	61°F

Technician Signature: _____

Customer Signature: _____