



Customer: Central States Diesel Generators STK#2768  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 262-955-7655

R#: 10198  
 Test Date 11-9-20

Engine Make/ Model: Cummins KTTA19-G2  
 Engine Spec/ Serial: 37153209  
 Unit Make/ Model: Cummins 500DFFB  
 Unit Spec/ Serial: G940550440 Spec. 69599K

Voltage: 277/480  
 Amperage: 602  
 Kilowatts: 500  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	485.8	486	486.3	486.5	486.8	486.9
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	483	483	483	483	483	483
PH2	484	484	484	484	484	484
PH3	483	483	483	483	483	483
Amperage PH1	0	597	598	598	598	0
PH2	0	598	598	598	599	0
PH3	0	599	599	599	598	0
Kilowatts	0	500	500	500	500	0
Oil Pressure	65	62	60	60	60	62
Oil Temperature						
Coolant Temperature	175°F	185°F	185°F	185°F	186°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27	27	27	27	27	27
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	66°F	66°F	65°F	65°F	65°F	64°F

Technician Signature: \_\_\_\_\_

Customer Signature: \_\_\_\_\_