



Customer: Central States Diesel Generators STK#2769
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: CEES
 Test Date 9-29-20

Engine Make/ Model: Cummins QSX15-G9
 Engine Spec/ Serial: 79121789
 Unit Make/ Model: Cummins DFEH-5710996
 Unit Spec/ Serial: H050813938 Spec. E

Voltage: 277/480 (multi-select)
 Amperage: 481
 Kilowatts: 400 (test@480V)
 Power Factor 0.8

| | 5 Min. | 15 Min. | 30 Min. | 45 Min. | 1 Hour | Cool Down |
|----------------------|--------|---------|---------|---------|--------|-----------|
| Eng Hours | 8988 | 8988.2 | 8988.5 | 8988.7 | 8989 | 8989.1 |
| Hertz/Cycles | 60 | 60 | 60 | 60 | 60 | 60 |
| Voltage PH1 | 481 | 481 | 481 | 481 | 481 | 481 |
| PH2 | 480 | 480 | 480 | 480 | 480 | 480 |
| PH3 | 481 | 481 | 481 | 481 | 481 | 481 |
| Amperage PH1 | 0 | 483 | 481 | 481 | 483 | 0 |
| PH2 | 0 | 482 | 480 | 479 | 480 | 0 |
| PH3 | 0 | 482 | 481 | 482 | 481 | 0 |
| Kilowatts | 0 | 400 | 400 | 400 | 400 | 0 |
| Oil Pressure | 45 | 40 | 38 | 38 | 38 | 40 |
| Oil Temperature | | | | | | |
| Coolant Temperature | 175°F | 180°F | 180°F | 180°F | 180°F | 178°F |
| Man Vac./Press. L/B | | | | | | |
| Man Vac./Press. R/B | | | | | | |
| L/B Exhaust Temp | | | | | | |
| R/B Exhaust Temp | | | | | | |
| Exhaust Temperature | | | | | | |
| DC Voltage | 24.7 | 24.7 | 24.7 | 24.7 | 24.7 | 24.7 |
| Natural Gas Pressure | | | | | | |
| Diesel Fuel Level | | | | | | |
| Room Temperature | | | | | | |
| Ambient Temperature | 75°F | 75°F | 75°F | 75°F | 76°F | 76°F |

Technician Signature: _____

Customer Signature: _____