



Customer: Central States Diesel Generators STK#2770  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 262-955-7655

R#: 10078  
 Test Date 9-25-20

Engine Make/ Model: Cummins NTA-855-G5  
 Engine Spec/ Serial: 30364948  
 Unit Make/ Model: Cummins DFCE-4488936  
 Unit Spec/ Serial: J000159967 Spec. D

Voltage: 277/480  
 Amperage: 481  
 Kilowatts: 400  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	405	405.2	405.5	405.7	406	406.1
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	480	480	480	480	480
PH2	480	480	480	480	480	480
PH3	480	480	480	480	480	480
Amperage PH1	0	481	482	481	481	0
PH2	0	482	481	482	482	0
PH3	0	482	481	482	481	0
Kilowatts	0	400	400	400	400	0
Oil Pressure	68	63	61	61	61	64
Oil Temperature						
Coolant Temperature	182°F	190°F	190°F	190°F	190°F	183°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.8	27.8	27.8	27.8	27.8	27.8
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	74°F	74°F	74°F	75°F	75°F	75°F

Technician Signature: Randy Pool

Customer Signature: \_\_\_\_\_