



Customer: Central States Diesel Generators STK#2771
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 10079
 Test Date 9-25-20

Engine Make/ Model: Cummins NTA-855-G5
 Engine Spec/ Serial: 30364848
 Unit Make/ Model: Cummins DFCE-4488936
 Unit Spec/ Serial: J000159968 Spec. D

Voltage: 277/480
 Amperage: 481
 Kilowatts: 400
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	439.8	440	440.3	440.5	440.8	440.9
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	479	479	479	479	480
PH2	479	479	479	479	479	479
PH3	479	479	479	480	479	479
Amperage PH1	0	483	482	481	483	0
PH2	0	482	482	483	482	0
PH3	0	482	483	482	482	0
Kilowatts	0	400	400	400	400	0
Oil Pressure	56	48	47	47	47	52
Oil Temperature						
Coolant Temperature	180°F	186°F	186°F	187°F	186°F	183°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.7	27.7	27.7	27.7	27.7	27.7
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	75°F	75°F	75°F	75°F	76°F	76°F

Technician Signature: Randy Pool

Customer Signature: _____