



Customer: Central States Diesel Generators STK#2772  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 262-955-7655

R#: 10150  
 Test Date 9-29-20

Engine Make/ Model: Caterpillar 3306  
 Engine Spec/ Serial: 9NR04718  
 Unit Make/ Model: Caterpillar 3306  
 Unit Spec/ Serial: 9NR04718

Voltage: 277/480  
 Amperage: 301  
 Kilowatts: 250  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	627	627	627	627	628	628
Hertz/Cycles	60.1	60.1	60.1	60.1	60.1	60.1
Voltage PH1	482	482	482	482	482	482
PH2	481	481	481	481	481	481
PH3	482	482	482	482	482	482
Amperage PH1	0	300	300	300	300	0
PH2	0	300	299	299	300	0
PH3	0	299	300	300	300	0
Kilowatts	0	250	250	250	250	0
Oil Pressure	64	60	59	59	59	61
Oil Temperature						
Coolant Temperature	175°F	178°F	178°F	178°F	178°F	177°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27	27	27	27	27	27
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	48°F	48°F	48°F	49°F	49°F	49°F

Technician Signature: Randy Pool

Customer Signature: \_\_\_\_\_