



Customer: Central States Diesel Generators STK#2777
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 10159
 Test Date 10-15-20

Engine Make/ Model: Detroit Diesel 8V-92TA
 Engine Spec/ Serial: 08VF175621
 Unit Make/ Model: Kohler Sprectrum 400DS60
 Unit Spec/ Serial: 395012

Voltage: 277/480
 Amperage: 481
 Kilowatts: 400
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	1015	1015.2	1015.5	1015.7	1016	1016.1
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	484	484	484	484	484	484
PH2	484	484	484	484	484	484
PH3	483	483	483	483	483	483
Amperage PH1	0	478	478	478	478	0
PH2	0	478	478	478	478	0
PH3	0	479	479	479	479	0
Kilowatts	0	400	400	400	400	0
Oil Pressure	70	65	64	64	64	65
Oil Temperature						
Coolant Temperature	155°F	165°F	165°F	165°F	165°F	160°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28.2	28.2	28.2	28.2	28.2	28.2
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	48°F	48°F	49°F	49°F	49°F	50°F

Technician Signature: Randy Pool

Customer Signature: _____