



Customer: Central States Diesel Generators STK#2779  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 262-955-7655

R#: 10200  
 Test Date 10-27-20

Engine Make/ Model: Caterpillar C27  
 Engine Spec/ Serial: MJE01642  
 Unit Make/ Model: Caterpillar C27  
 Unit Spec/ Serial: DWB01644

Voltage: 277/480  
 Amperage: 842  
 Kilowatts: 700  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	133.8	134	134.3	134.5	134.8	134.9
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	481	481	481	481	481	481
PH2	480	480	480	480	480	480
PH3	478	478	478	478	478	478
Amperage PH1	0	842	841	842	842	0
PH2	0	841	841	840	841	0
PH3	0	840	842	841	840	0
Kilowatts	0	700	700	699	700	0
Oil Pressure	73	65	63	63	63	65
Oil Temperature						
Coolant Temperature	175°F	180°F	180°F	180°F	180°F	178°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.1	27.1	27.1	27.1	27.1	27.1
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	38°F	38°F	38°F	39°F	39°F	39°F

Technician Signature: \_\_\_\_\_

Customer Signature: \_\_\_\_\_