



Customer: Central States Diesel Generators STK#2782
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 10195
 Test Date 11-19-20

Engine Make/ Model: John Deere 4045HF285
 Engine Spec/ Serial: PE4045L226102
 Unit Make/ Model: Wacker Neuson G100
 Unit Spec/ Serial: 20172444

Voltage: 277/480 (multi-select)
 Amperage: 96
 Kilowatts: 80
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	12079.3	12079.5	12079.8	12080	12080.3	12080.4
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	481	481	481	481	481	481
PH2	481	482	482	482	482	481
PH3	479	479	479	479	479	479
Amperage PH1	0	96	96	96	97	0
PH2	0	97	96	97	96	0
PH3	0	97	97	97	97	0
Kilowatts	0	80	80	80	80	0
Oil Pressure	51	48	46	46	46	49
Oil Temperature						
Coolant Temperature	182°F	193°F	194°F	194°F	194°F	184°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	14	14	14	14	14	14
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	48°F	48°F	48°F	49°F	49°F	49°F

Technician Signature: _____

Customer Signature: _____